LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/10/2020 Expiration Date: 07/10/2021

Property Owner: Bob Payne c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: Tally Hoe License No.

___ New Installation __XX__ Existing System

____ Repair ____ Replacement __XX__ Extension ____ Other

Describe: Add 1000 tank in line total 2 tanks 2000 gal and more drainfield. Adding Two 72' laterals with chambers.

Parcel Description:

Legal: S03, T30 N, R31 W, TR 1 IN NE 15.3702 ACRES MOUNTAIN VIEW TRAILER COURT

Address or Location: Tract 1

Geo/Assessors code: 0000008588

Approved Design Criteria:

Bedrooms Septic Tank Size: 2-1000 gallons Drainfield Size: lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Thomas J Cole *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Thomas J Cole *Date:* 7-14-20

Title: owner operator

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

72'
72'
72'
72'
12'
well