LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/09/2019 Expiration Date: 12/09/2020

Property Owner: Cloyd Peterson c/o:

Address: [redacted]

Telephone: [redacted] (Work) 885-1422

Installer: Koocanusa Excavating License No.135

___ New Installation ___xx_ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 64' Laterals using perp pipe & drain rock

Parcel Description:

Legal: FORTINE SUBD, S25, T35 N, R26 W, BLOCK 4, Lot 8 - 14, SEC 25 & 36

Address or Location: LOT 8-14

Geo/Assessors code: 0000000976

Approved Design Criteria:

Bedrooms : 2 1-bedroom houses Septic Tank Size: 1000/500 gallons Drainfield Size: (3) 64'Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Buck Schermerhorn, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Buck Schermerhorn *Date:* 12/11/19

Title: President


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

REV	DESCRIPTION	BY/DATE	APPD/DATE



CLOYD PETERSON 235 1ST STREET SOUTH FORTINE, MT 59918

REV	DATE	COMPANY	SCALE:	KOOCANUSA EXCAVATING PETERSON SEPTIC
		KEI	1/16 = NOTED	SITE LAYOUT
		CONTRACT:	DATED: 12/19	12/3/19
		VERBAL		C. PETERSON 12/XX/19
		PLOT FILE: PML-0001	WEIGHT:	CLOYD-001 1

THIS DRAWING IS PROPERTY OF KEI UNTIL CONTRACT HAS BEEN SECURED BETWEEN OWNER & KEI IT CAN NOT BE SUBMITTED TO ANY OTHER PARTIES WITHOUT WRITTEN APPROVAL FROM KEI MANAGEMENT