SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent ____

Phone 773-3416

Date 5-12-80

Property Owner Pine Creek Community Church Address ____

(C/O) Erv Holk


Lot, Block Number, or legal description of Property SE1/4 NW1/4 Sec 2 T 31N R

To be built by: D. Sweet Square feet absorption area. 360


Septic Tank Size 1000 gl # of bedrooms — Water Supply well

Description of Absorption Area: Dig a trench 1½' wide x 2½-3' deep x 2' wide rock to 1'- Input - 6" tile - drain... Slope of pipe 3" per 10' Fall = 1½ deep

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



LOT LAYOUT



SOIL: Silt loam

SLOPE: 0%

Issued by John D. Peterson, RS Inspected by ____

Date 5-12-80

NOTE - A Lift Station will be required between the Septic T... and Drainfield if tank must be set too deep for drain...