LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

RE-ISSUE
9830

Issue Date: 06/21/05

Expiration Date: ~~5/1/2021~~ 5/7/2021

Property Owner: THOMAS QUIN

c/o: Davis Surveying

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: ANTHONY BERGET License No. 26

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe:

Parcel Description:

Legal: S2 T31 R34 ASSESMENT CODE: 0000009831

Address or Location: Lot 10 in Valley Tracts

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 210 Linear Feet/180 LF

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING LOT LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, ANTHONY J. BERGET, *have inspected this system and found it to be in compliance with the conditions of the permit and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Anthony J. Berget *Date:* 7/14/20

Title: INSTALLER


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY, MONTANA
SEPTIC TANK PERMIT
VALLEY TRACTS
IN THE NE 1/4 OF SECTION 2
TWP. 31 N., R. 34 W., P.M.M.
FOR: MONTANA MOUNTAIN VALLEY L.L.C. DATE: MAY 2005
LOT 10



06/20/05

SCALE
1 INCH = 100 FT.

Davis Surveying Inc.
TROY MONTANA, (406)295 5441

DATE: 05/18/05	
DRAWN BY: MDM	FILE: t31r34s2.DWG