Easter

SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 8-17-76

Phone ——

Property Owner John Scott Address Box 432 Troy

Lot, Block Number, or legal description of Property Lot 11 Block 9 Kootenai Vista


To be built by: McDougall Square feet absorption area. 2200 sq. ft.

Septic Tank Size 750 gal # of bedrooms 2 Water Supply well


Description of Absorption Area: Dig a ditch 110' in length x 2½-3' deep x 2' wide according to lot layout and ditch diagram. Keep pipe level, about 1% deep.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.

Lot layout



Ditch diagram



Soil: gravel

Issued by Ron Anderson Inspected by _____

Date 8-17-76