LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 9/6/2019 Expiration Date: 9/6/2020

Property Owner: Edward Stoken c/o:

Address: [redacted]

Telephone: (Work) [redacted]

Installer: Brennemans Excavation License No. 170

xx New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 84' Laterals in gravelless chamber

Parcel Description:

Legal: S12, T35 N, R26 W, ACRES 141.795,

Address or Location: 104 STOKEN Rd EUREKA, MT

Geo/Assessors code: 0000000957

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size 252 linear ft

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Elmer Brenneman, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Elmer Brenneman *Date:* 10-5-2019

Title: Elmer Brennemans Excavation

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly

LOT LAYOUT

