LINCOLN COUNTY
SEPTIC SYSTEM PERMIT NO. New

ISSUED TO: DAN & CONNIE SWARTZENBRUBER DATE: 10-2-86

ADDRESS: 5358 Pipe Creek Rd Libby PHONE: [redacted]

ISSUED BY (sign.) Johnny Peterson, RS

INSPECTION BY (sign.) _____ DATE: _____

(You must notify the Department of Environmental Health a minimum of 8 working day hours before backfilling the septic system, so that it can be inspected.)

CONTRACTOR: L. C. Thom

DESCRIPTION OF SYSTEM:

LOCATION OF PROPOSED SYSTEM Sec 10 T32N R31W - Pipe Cr. Rd

SEPTIC TANK Proposed 1000 gal. ABSORPTION AREA: 240 ft²

SEWAGE DISCHARGE ~ gal/day No. OF BEDROOMS 2

WATER SUPPLY SOURCE Well SOIL Gravelly loam SLOPE 0-20

INSTRUCTIONS: Drainfield Dig a ditch 120' long x 2½-3' deep x 2' wide according to lot layout & septic system reg. Slope of pipe should not be less than a 1% drop.

SKETCH OF LOT LAYOUT:

