# LINCOLN COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
# WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 9/6/2019 Expiration Date: 9/6/2020

Property Owner: Steve & Debbie Wilson c/o:

Address:

Telephone: (cell) [redacted] (Work)

Installer: License No.

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 100' laterals using gravelless chambers

*Parcel Description*:

Legal: ELK HAVEN HIDEAWAY, S22, T37 N, R31 W, LOT 7

Address or Location: 374 Lone Wolf Trl Troy, MT 59935

Geo/Assessors code: 00000050523

*Approved Design Criteria*:

# Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size 200 linear ft

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!**

***Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

**Issued By:** Jake Mertes, R.S.

Closure Statement:

*I,* JAKE MERTES *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*


*Signed:* _____ *Date:* 5/28/2020

*Title:* LOCAL SANITARIAN

**NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

**406-283-2442**

***DISCLAIMER***


263.04
117.40
146.94
72.94
TILITY EASEMEN)
30'
(COS 1595)
N00°14'19"E 1511.69
(N00°14'27"E 1511.74'
179.86
EASEMENT
R=50.00
Δ=35°50'43"
L=31.28
R=50.00
Δ=36°33'01"
L=31.90
S83°56'43"W 255.07
ELK HAVEN ROAD
S83°56'43"W 255.07
335.54
20'
20'
S89°48'51"E
512.93
542.93
LOT 7
3.334 ACRES
Residential
R=40.00
Δ=66°17'36"
L=46.28
S83°56'43"W 616.33
40.00
40.00
R=40.00
Δ=150°00'00"
L=104.72
R=40.00
Δ=83°42'24"
L=58.44
240.80
903.66)
295.29
TRACT 3, COS No. 1595
LARRY & PAMELA COVEY