LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/5/2016 Expiration Date: 12/5/2017

Property Owner: Andy Yoder c/o: Enviro-Tech

Address: [redacted]

Telephone: (Home) (Work) [redacted]

Installer: License No.

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Four 93' laterals using drainrock and perforated pipe.

Parcel Description:

Legal: S9 T37 R28

Address or Location: NWNE Tract 4B

Geo/Assessors code: 0000012621

Approved Design Criteria:

Bedrooms 2+1 Septic Tank Size: 1000 gallons Drainfield Size: 375 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Evan Miller, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Evan Miller *Date:* 4/17/2017

Title: installer

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442


DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Legend

- ⊠ test hole
- ═ proposed drainfield site
- ▭ proposed replacement area
- ⓐ proposed well site w/ 100' isolation zone
- ▱ mixing zone

Name: Yoder- Tract 4B
County: Lincoln
Location: NWNE¼
sec.9-T37N-R28W
E.Q.#



Enviro-Tech
Consulting Inc.
Brian S. Launius
PO Box 5674
Kalispell, MT 59903
(406)257-2795