LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 5/8/2019 Expiration Date: 5/8/2020

Property Owner: Lester Yoder c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: Ivan Miller License No. 52

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 80' laterals using drain rock and perf pipe.

Parcel Description:

Legal: S15 T37 R28

Address or Location: COS 3319 Parcel A-2

Geo/Assessors code: 0000012658

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 240 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442


DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

XS

LINCOLN COUNTY, MONTANA
LOT LAYOUT
IN THE NE 1/4 OF SECTION 15 TWP. 37 N., R. 28 W., P.M.M.
FOR: JONAS YODER DATE: SEPTEMBER 2003

Hi. Can you please send me a permit for a Septic for 161 Tumbleweed Tr. Rexford Mt. 59930 Thanks Lester Ray Yoder 406-334-7371



LEGEND
- SOILS PROFILE
- PERCOLATION SITE
- PROPOSED WELL SITE
- SLOPE
- GRADIENT DIRECTION
- PROPOSED SEPTIC SITE 3-80' TRENCHES 10' APART
- REPLACEMENT SITE 3-80' TRENCHES 10' APART
- 500' MIXING ZONE
- SWALE

APPROVED
Montana Department of Environmental Quality
Permitting and Compliance Division
Reviewer 4-13-04 Date

RECEIVED
APR 19 2004
MT DEQ PUBLIC WATER & SYSTEMS BUREAU

SCALE 1 INCH = 200'

DAVIS SURVEYING INS.
(406)295-5441
SEPTEMBER 2003
DRAWN BY: RES | FILE: T372815

2BR 1265g

IVAN MILLER