LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 8/27/2018 Expiration Date: 8/27/2019

Property Owner: Jack Beddall c/o: Koocanusa Excavating

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: Koocanusa Excavating, Inc License No. 135

__xx__ New Installation ___ Existing System

___ Repair ___ Replacement ____ Extension ____ Other

Describe: Three 88' laterals using drain rock and perf pipe.

Parcel Description:

Legal: S32 T35 R26

Address or Location: CS 3638 Tract 2

Geo/Assessors code: 0000014294

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 264 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Buck Schermerhorn *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 9-21-18

Title: President


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

REV	DESCRIPTION	BY/DATE	APRD/DATE



BEDDALL SEPTIC SYSTEM LAYOUT

REV	DATE	COMPANY	SCALE
		KEI	1/16 = 1'-0"

KOOCANUSA EXCAVATING
BEDDALL PROJECT
SEPTIC PERMIT
6/1/18
A. BEDDALL 6/1/18
062417-001 1

THIS DRAWING IS PROPERTY OF KEI (PTE) LTD. COPYRIGHT
THE DESIGN CONTAINED HEREIN IS NOT
IT CAN NOT BE SUBMITTED TO ANY OTHER PARTIES
WITHOUT WRITTEN APPROVAL FROM KEI ENGINEERS

⑥ ⑤ ④ ③ ②