LINCOLN COUNTY HEALTH DEPARTMENT Permit #24-14594
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/31/2024 Expiration Date: 12/30/2025

Property Owner: Cedar Creek Holdings LLC 14594

Mailing Address: [redacted]

Installer: Tyler Hartz License #: 212

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new pressure dosed system for 3 Bedroom House.

Legal: BARNABY HEIGHTS, S28, T35 N, R26 W, LOT 29, ACRES 1.22, PM 7081

Property Address: Lot 29 Osprey Loop Fortine, MT 59918 Assessment Code: 14594

DEQ COSA: E.Q.# 23-2694 Date: 01/16/2024

Approved Design Criteria: Installation of new pressure dosed system for 3 Bedroom House with 4 Laterals @ 94' with reduction for chambers.

# of Bedrooms: 3 Septic Tank Size: 1000/500 gallons Trench Width: 36"

# of Laterals: 4 Length of Laterals: 94' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 9/4/25


This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

Eastridge Heights Subdivision
W½ NW¼ of Section 28 T35N
R 26 W P.M. - Lincoln County, MT

E

Lot 29



W