LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 7/3/2019 Expiration Date: 7/3/2020

Property Owner: Dan Knapp c/o: Terry Oedewaldt

Address: [redacted]

Telephone: (Home) (Work)

Installer: Terry Oedewald License No. 002

____ New Installation __xx__ Existing System

____ Repair __xx__ Replacement ____ Extension ____ Other

4 EACH BED using gravelless chambers.

Parcel Description:

Legal: S26 T31 R31

Address or Location: CS 1490 Parcel B

Geo/Assessors code: 0000009385

Approved Design Criteria:

Bedrooms 4 Septic Tank Size: 1500 gallons Drainfield Size: 14 x 40 BED

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, TERRY OEDEWALDT, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 7/8/2019

Title: PRESIDENT

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

DAN KNAPP 7/8/2019

LOCATIONS:	A	B
INLET	13' 8	9' 9
FILTER	19' 3	20' 9

