LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/11/2017

Expiration Date: 12/11/2018

Property Owner: Dawson McCully

c/o: Bruce Todd

Address: Box 1698 Eureka, MT 59917

Telephone: (Home) [redacted]

(Work)

Installer: Bruce Todd

License No. 54

____ New Installation ___xx_ Existing System

____ Repair ___xx_ Replacement ____ Extension ____ Other

Describe: Three 75' laterals using gravelless chambers.

Parcel Description:

Legal: S11 T36 R27

Address or Location: CS 313 TR 1B & 1C 516 Mill Springs Road

Geo/Assessors code: 0000007174

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 225 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Bruce Todd, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Bruce C. Todd *Date:* 10-29-2018

Title: INSTALLER

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

WELL
50'
ASPHALT
CH
310'
HOUSE
30'
CAR PORT
SEPTIC TANK
BOX
75'
REPLACEMENT AREA
SHED
DRIVE WAY
110'
155'
MILLSPRINGS RD.
275'