LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 7/25/2019 Expiration Date: 7/25/2020

Property Owner: Paul Nicely c/o: Debra Deeds

Address: [redacted]

Telephone: (Home) (Work)

Installer: Terry Oedewald License No. 002

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 45' pressure dosed laterals using 3' wide gravelless chambers.

Parcel Description:

Legal: S14 T31 R32

Address or Location: Big Horn Terrace Lot A

Geo/Assessors code: 0000002592

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000/500 gallons Drainfield Size: 90 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, TERRY OEDEWALD *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 7/27/19

Title: PRESIDENT

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

PAUL NICELY 7/27/2019

LOCATIONS:	A	B
INLET	15'7	28'3
FILTER	22'6	32'5
PUMP	26'3	35'2
E BOX	24'10	35'2
START #1 LEG	38'4	41'
END #1 LEG	85'	83'4
START # 2 LEG	39'8	37'4
END # 2 LEG	85'2	81'

