LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 8/28/2018 Expiration Date: 8/28/2019

Property Owner: Mikel Parrish c/o: Ryan Blekkenk

Address: [redacted]

Telephone: (Home) (Work)

Installer: Alpine Haven Builders License No. 172

____ New Installation __xx__ Existing System

___ Repair ___ Replacement __xx__ Extension ____ Other

Describe: Adding 47' of lateral and connecting existing cabin to system.

Parcel Description:

Legal: S30 T27 R27

Address or Location: Upper Thompson Lake Shore Lot 10

Geo/Assessors code: 0000003018

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 141 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Ryan Blekkenk, AHB, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Ryan Blekkenk *Date:* 10-13-18

Title: Owner Alpine Haven Builders

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

595 Lakeshore Drive

