# LINCOLN COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
# WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 6/22/2018 Expiration Date: 6/22/2019

Property Owner: Mike Shira c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: Terry Oedewaldt License No. 02

___ New Installation ____ Existing System

____ Repair __xx__ Replacement ____ Extension ____ Other

Describe: Three ring drywell to replace failed system.

*Parcel Description*:

Legal: S26 T32 R34

Address or Location: COS 700 Parcel A Tract 1DDA

Geo/Assessors code: 0000006412

*Approved Design Criteria*:

# Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 3 Drywell Rings

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!**

***Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

**Issued By:** Jake Mertes, R.S.

Closure Statement:

I, TERRY OEDEWALDT, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

*Signed:* _____ *Date:* 9/12/2018

*Title:* PRES.

**NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

**406-283-2442**

***DISCLAIMER***

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

MIKE AND PAT SHIRA
6/18/18
150 PARSON DRIVE
TROY, MT

LOCATIONS:

| | A | B |
|---|---|---|
| INLET | 21'2 | 19'10 |
| OUTLET | 16'8 | 25'3 |
| DRY WELL 1 | 25'9 | 56' |
| 2 | 30'10 | 61'5 |
| 3 | 35'9 | 66'7 |

