LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/19/2017 Expiration Date: 10/19/2018

Property Owner: Don Smith c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: License No. 99

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Five 100' laterals using drain rock and perf pipe.

Parcel Description:

Legal: S16 T33 R34

Address or Location: Tract 2C1 COS 1079

Geo/Assessors code: 0000010982

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 500 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: Duane Smith *Date:* 11-2-17

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442


DISCLAIMER


This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY MONTANA

LOT LAYOUT:

RE-WRITE OF OCCASIONAL SALE
TRACT PER C.O.S. NO. 1079
In the NW1/4 NW1/4 of Section 16,
Twp. 33 N., R. 34 W., P.M.M.
For: Donald R. Smith
Date: September 2017





NOTES:

NO EXISTING WELLS OR DRAINFIELDS WITHIN 100' OF THE PROPERTY BOUNDARIES.

LANDOWNER IS RESPONSIBLE FOR MAINTAINING STORMWATER STRUCTURES.


GRADIENT DIRECTION

Reviewed by the Local Reviewing Authority
Under contract with the
Department of Environmental Quality

Local Reviewer — Date 10/16/17

Accepted under contract

N/A
DEQ Representative — Date



CABINET MOUNTAIN SURVEYING, LLC
TROY, MT 59935

DATE: 09/27/17	Land Projects 2017
DRAWN BY: MDM	FILE: T3334 16ds.dwg