LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 8/16/2018 Expiration Date: 8/16/2019

Property Owner: Stephen Smith c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: John Ramesz License No. 28

____ New Installation __xx__ Existing System

__xx__ Repair ___ Replacement ____ Extension ____ Other

Describe: Repairing pressurized drainfield.

Parcel Description:

Legal: S11 T36 R27

Address or Location: Parcel A CS 4416

Geo/Assessors code: 0000007555

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000/500 gallons Drainfield Size: 187 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, John Ramesz, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: John Ramesz *Date:* 10/1/18

Title: Installer


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT


N
S
well
ROAD
Proposed House
out building
HILL
Terrace
Existing slope
Carport
Building
Drainage