LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 9/21/2017 Expiration Date: 9/21/2018

Property Owner: Don Truman c/o: Enviro-tech

Address: PO Box 5674

Telephone: (Home) [redacted] (Work)

Installer: License No.

__xx__ New Installation ___ Existing System

____ Repair _____ Replacement ____ Extension ____ Other

Describe: Four 95' laterals using drain rock and perf pipe.

Parcel Description:

Legal: S26 T37 R28

Address or Location: Tract 1 COS 4375

Geo/Assessors code: 0000010683

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 375 linear feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Jake Mertes, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442


DISCLAIMER


This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Legend

- ⊠ test hole
- ≡ proposed drainfield site
- ▭ proposed replacement area
- ⚠ proposed well site w/ 100' isolation zone
- ▱ mixing zone

Name: Truman
County: Lincoln
Location: sec.26-T37N-R28W
E.Q.#





Enviro-Tech
Consulting Inc.
Brian S. Launius
PO Box 5674
Kalispell, MT 59903
(406)257-2795