LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 5/19/2017 Expiration Date: 5/19/2018

Property Owner: Klaus VandeOever c/o: Koocanusa Plumbing

Address: PO BOX 2045

Telephone: (Home) [redacted] (Work)

Installer: Koocanusa Plumbing License No. 8

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 84' trenches using gravelless chambers, size reduced per app rate.

Parcel Description:

Legal: S33 T36 R26

Address or Location: Glen Lake Hill South Lot 4C

Geo/Assessors code: 0000054508

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 252 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Michael Nelson, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 24 May 2017

Title: Installer #E

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

NW1/4NW1/4, SECTION 33, T. 36 N., R. 26 W., P.M.,MT.
LINCOLN COUNTY, MONTANA
FOR: WAELTI-CAMM JULY 2003

