Issue Date: 09/14/01 Expiration Date: 09/15/02

Property Owner: David G. Walker c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: Rupert Schreiner License No. 19

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe:

Parcel Description:

Legal: S15 T37 R27 Lot 4A2 – Jim Creek Woods

Address or Location: Jim Creek Road – Trego

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 340 linear feet

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*


Closure Statement:

I, Rupert Schreiner *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Rupert Schreiner *Date:* 10-9-2001

Title: Li # 19

LOT LAYOUT
DAVID WALKER
LOT 4A2
JIM CREEK WOODS



SCALE: 1" = 100'