LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 3/6/2019

Expiration Date: 3/6/2020

Property Owner: Rhonda Williams

c/o: Barb Renkema

Address: [redacted]

Telephone: (Home) [redacted]

(Work)

Installer: Barb Renkema

License No. 78

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Five 88' pressure dosed laterals using gravelless chambers.

Parcel Description:

Legal: S36 T33 R27

Address or Location: 5000 Lake Creek Road, Trego, MT 59934

Geo/Assessors code: 0000012234

Approved Design Criteria:

Bedrooms 2/2 Septic Tank Size: 1500/500 gallons Drainfield Size: 440 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Jake Mertes, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

5000 Lake Creek Rd

S 36 T 33N R 27W

111.55 A.

