LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 5/09/2019 Expiration Date: 5/09/2020

Property Owner: Darrell Willso c/o:

Address: 44804 SE 166th Street, Northbend, WA

Telephone: (Home) 425-888-0597 (Work)

Installer: Dwane Smith License No. 99

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 100' laterals using drain rock and perf pipe..

Parcel Description:

Legal: S05 T33 R34

Address or Location: Harrell's Subdivision Lot 1A

Geo/Assessors code: 0000021002

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 300 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Melvin, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Melvin O Smith *Date:* 7-12-19

Title: E.T.C. owner

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY MONTANA

LOT LAYOUT:

REVISED LOT 1A OF C.O.S. NO. 4428RB
In the NW1/4 NE1/4 of Section 05,
Twp. 33 N., R. 34 W., P.M.M.
For: Darrell D. & Pamela M. Willson
Date: April 2018

LEGEND

PROPOSED BUILDING SITE

EXISTING WELL SITE


SLOPE

NEW SEPTIC SITE MUST COMPLY WITH THE STATE DEQ APPROVAL PER E.Q. #08-2388

NEW REPLACEMENT SITE MUST COMPLY WITH THE STATE DEQ APPROVAL PER E.Q. #08-2388

NOTES:
NO EXISTING WELLS OR DRAINFIELDS WITHIN 100' OF THE PROPERTY BOUNDARIES.

STANDARD SEPTIC SYSTEM



Reviewed by the Local Reviewing Authority
Under contract with the
Department of Environmental Quality

Local Reviewer — Date 4/17/2019

Accepted under contract

DEQ Representative — Date

Graphic Scale:

200 0 100 200

1 inch = 200 ft.

CABINET MOUNTAIN SURVEYING, LLC
TROY, MT 59935

DATE: 04/10/19	Land Projects 2019
DRAWN BY: MDM	FILE: t33r34s5.dwg