LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/20/2017 Expiration Date: 10/20/2018

Property Owner: Mark Farr c/o: Ken Davis

Address:

Telephone: (Home) (Work)

Installer: Redlinger License No.

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Four 50' laterals using drain rock and perf pipe.

Parcel Description:

Legal: S20 T29 R33

Address or Location: Parcel D COS 3996

Geo/Assessors code: 0000014350

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 200 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY MONTANA

LOT LAYOUT:

PARCEL D OF C.O.S. NO. 3996

In the SW1/4 SE1/4 of Section 20, Twp. 29 N., R. 33 W., P.M.M.

For: Mark R. Farr Date: October 2017


MONTANA HIGHWAY NO. 56

Drainfield: 400 sq.ft.

2 Bedroom = 200gpd / Application Rate = 0.6 = 333 sq.ft.

PARCEL D

28.626 ACRES±



Graphic Scale:

100 0 50 100

1 inch = 100ft.