LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/18/2015 Expiration Date: 05/19/2016

Property Owner: Nathan & Ann Gassmann c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: License No.

____ New Installation __XX__ Existing System

_____ Repair _____ Replacement __XX__ Extension _____ Other

Describe: Adding 200-feet to existing system to accommodate future 2-bedroom expansion.

Parcel Description:

Legal: S9 T30 R31 Lot 3 of Parmenter Heights

Address or Location: 970 Taylor Road

Approved Design Criteria:

Bedrooms: 4 Septic Tank Size: 1000 gallons Drainfield Size: 420 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL ADDITIONAL 200-FEET OF DRAINFIELD ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, Charles J Riley *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Charles J Riley *Date:* 7-1-15

Title: owner

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

TAYLOR LOOP ROAD

