LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 7/5/2017 Expiration Date: 7/5/2018

Property Owner: Brent Holder c/o: Koocanusa Excavating, Inc.

Address: PO BOX 1188 Eureka, MT 59917

Telephone: (Home) [redacted] (Work)

Installer: Koocanusa Excavating, Inc. License No. 135

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Four 94' laterals using drain rock and perf pipe.

Parcel Description:

Legal: S6 T34 R26

Address or Location: Whispering Pines Koocanusa 5 Lot 8

Geo/Assessors code: 0000000862

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 375 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Jake Mertes, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____


Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.



REV	DATE	COMPANY	SCALE:	MOUNTAIN DESIGN SERVICES, INC. P.O. BOX 1855 EUREKA, MT 59917 406-883-4121	KOOCANUSA EXCAVATING WHISPERING PINES
		KEI	1/16 & NOTED		HOLDER LOT LAYOUT
		CONTRACT:	DATE:	DWG TOLERANCES:	DRAWN BY: 6/20/17
		VERBAL	6/19/17		APPROVED BY: B. HOLDER 6/20/17
		PLOT FILE:	WEIGHT	FINISH	DWG FILE NAME: 02917-001 SHEET NO. 1
		PML-0001	---		

③ ②