LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 08/11/2025 Expiration Date: 08/10/2026 Permit#25-10602

Property Owner: Josh Kendze

Mailing Address: [redacted]

Installer: Richard Luciano License #: 3

Approved Work: (Check One) ☐ New Installation ☒ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of an additional tank for Two 1 Bedroom Cabins to connect to shared system not to exceed 300 GPD total.

Legal: SKYVIEW, S14, T36 N, R28 W, LOT 4A, ACRES 3.388, CS 4292

Property Address: 260 Skyview Dr., Rexford, MT 59930 Assessment Code: 10602

DEQ COSA: E.Q.# 25-2231 Skyview Date: 7/1/25

Approved Design Criteria: Installation of an additional tank for Two 1 Bedroom Cabins to connect to shared system not to exceed 300 GPD total.

# of Bedrooms: Two 1 Bedroom Cabins Septic Tank Size: 2 X 1000 Trench Width:

# of Laterals: Length of Laterals: Trench Depth:

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, Circular DEQ-4, and COSA(If Applies). It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 10/7/25

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

Legend

- Soils test pit
- proposed & approved drainfield site
- proposed & approved replacement area
- proposed & approved well w/100' isloation zone
- provisional mixing zone
- proposed septic tank
- roadside swale & rention pond
- Building site


Name: Rereview of LOT 4A of Skyview Subdivision
ES#27-88-s27-733
County: Lincoln
Location- NW1/4 sec.14-T36N- R27W
EQ 25-2231

Proposed Additional Impervious Area
2- 1bdrm. cabins= 3,000 sf
Driveway= 6,420 sf

APPROVED
Montana Department of
Environmental Quality
Reviewer Date


COPY

Roadside Swale



NOTE- soil check dams of 6" deep x3 lineal feet shall be installed every 75 lineal feet of swale

NOTE-
1. No nearby well or septic systems within 100 ft. other that what is shown.
2. Drainfields exist within 500 ft. of proposed well.
3. Homeowners responsible for the maintenance of individual Stormwater Control Devices.
4. Homeowners to maintain check dams, culverts in road right-of-ways
5. Completion of the proposed subdivision will not increase the amount of pre-development, during a 100-year, 24 hour storm event, between proposed lots and from the proposed subdivision area to the ajoining properties. 17.36.310 (3)(e)
6. Each house foundation to be one foot above natural ground surface,
7. All wells to be constructed per ARM Title 36, Chapter 21, subchapter 6.
8. 10,000 sq. ft (minimum) of landscaping per new dwelling required



RECEIVED
JUN 19 2025
Subdivisions & Public Wa

Enviro-Tech
Consulting Inc.
Brian S. Launius
PO Box 5674
Kalispell, MT 59903
(406)257-2795