# LINCOLN COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
# WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 7/31/2017 Expiration Date: 7/31/2018

Property Owner: Bob Koenig c/o: Kent Hayes

Address: [redacted]

Telephone: (Home) (Work)

Installer: Kent Hayes License No. 144

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Four 74' pressure dosed laterals using 3' wide gravelless chambers. Size reduced (.8)

*Parcel Description*:

Legal: S11 T36 R27

Address or Location: Horizon Subdivision Lot 2

Geo/Assessors code: 0000053208

*Approved Design Criteria*:

# Bedrooms 4 Septic Tank Size: 1500/500 gallons Drainfield Size: 296 Linear Feet

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!**

***Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

**Issued By:** *Jake Mertes, R.S.*

Closure Statement:

*I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

*Signed:* _____ *Date:* _____

*Title:* _____

**NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

**406-283-2442**

***DISCLAIMER***

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

# LOT LAYOUT

Horizon Subdivision Lot 2

LOT LAYOUT
OBRIN & SUZANNE ELKINS
LOTS 2 & 3
HORIZON SUBDIVISION

