LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/02/2017 Expiration Date: 05/01/2018

Property Owner: Luke & Logan Letcher c/o:

Address: PO Box 1594, Eureka, MT 59917

Telephone: (Home) [redacted] (Work)

Installer: Kurt West License No. 166

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Repair ☐ Replacement ☐ Extension ☐ Other _____

Describe:

Parcel Description:

Legal: Heavenly View Lot 3, S14 T36N R27W

Address or Location:

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 Drainfield Size: 300 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kurt West

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: Kurt West *Date:* 10/10/2017

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

283-2440

406-293-7781 x228

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

OWNED

M
CTED

EXISTING 4" WATER MAIN PER MIDVALE PLANS

(20' WIDE PAVED DRIVING SURFACE)

PHONE
435.60' X
PED

217.80'

PROPOSED APPROACH

PROPOSED WATER SERVICE CONNECTION

4–75' TRENCHES
7' SPACING

PROPOSED HOME

NO WELLS OR SEPTIC WITHIN 100'

S13°09'37"E

199.85'

3% SLOPE

14% SLOPE

S13°10'57"E

Lot 3
1.00 Ac.

100% REPLACEMENT AREA

199.93'

110.66'

217.72'

435.45'

NO WELLS OR SEPTIC WITHIN 100'

ASIS OF BEARINGS PER PLAT #1726


NORTH

LEGEND

- P- HOMESITE
- P- DRAINFIELD AND REPLACEMENT SITE
- P- MIXING ZONE
- P- LOT BOUNDARY
- P/E- WATER LINE
- P- APPROACH
- SOILS PROFILE LOCATION
- SURFACE DRAINAGE FLOW DIRECTION
- P-(163 CF) HOME SITE STORM RETENTION SWALE

:ntion Swale Lot 3

R 24 HOUR
I CAPACITY



UME PER
FOOT

LAT BOTTOM WIDTH

48 NORTH p.c.
Civil Engineering Services

SEAL

SUBCONSULTANT

PATT TRUMAN SUBDIVISION
TRACT 5P AND 3S (IN MIDVALE)
SEC 11 AND 14 T 36N R 27W

DRAWING SET DATE
ISSUES\REVISIONS 1 = ISSUE
△ = REVISI

No.	Date	Purpose	By	Ch

PROJECT NUMBER
SHEET TITLE
FILE No.
BOOK | PAGE
DRAWN BY: B. MCCULLY

SHEET No. OF 1
LL