LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 3/18/2016

Expiration Date: 3/17/2017

Property Owner: Lincoln Electric

c/o: Enviro-Tech Consulting

Address: [redacted]

Telephone: (Home) [redacted]

(Work) [redacted]

Installer:

License No.

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 56' laterals, pressure dosed system in three foot wide trenches.

Parcel Description:

Legal: S2 T36 R27

Address or Location: HWY 93 and Lindsay Road Parcel 1 of COS# 2563

Geo/Assessors code: 000053290

Approved Design Criteria:

20 or less employees (200gpd) Septic Tank Size: 1000/500 gallons Drainfield Size: 112 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Jake Mertes, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442


DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Legend

- ⊠ test hole
- ||| proposed drainfield site
- □ proposed replacement area
- Ⓐ proposed well site w/ 100' isolation
- ▽ mixing zone

Name: Lincoln Electric Coop
Parcel 1 of COS#2563
County: Lincoln
Location: NW1/4 sec.2-T36N-R27W
E.Q.#



Enviro-Tech Consulting Inc.
Brian S. Launius
PO Box 5674
Kalispell, MT 59903
(406)257-2795