LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/06/2015 Expiration Date: 05/07/2016

Property Owner: Paul & Rubianna Masa c/o:

Address: P.O. Box 1551 Columbia Falls, MT 59912

Telephone: (Home) [redacted] (Work)

Installer: Shayne Nelson License No. 118

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Re-issue of 3/814 Wm. Konshur Permit. Shallow-capped gravelless chamber construction per DEQ approval – trench depth not to exceed 18-inches

Parcel Description:

Legal: SE-1/4 NE-1/4 S14 & SW-1/4 NW-1/4 S13 T27 R28

Address or Location: Lot 22 of Parkside at Fisher – 1212 Rogers Mtn. Loop

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 200 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: ***INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, SHAYNE NELSON *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] NELSON CONSTRUCTING *Date:* 5/18/15

Title: OWNER

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Kendra

Lot 22

LOT LAYOUT

