LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 7/15/2016 Expiration Date: 7/15/2017

Property Owner: John McCrorie c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: Self License No.

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 75' Trenches using gravelless chambers. Size reduced pre .8 app rate

Parcel Description:

Legal: S17 T34 R25

Address or Location: Cripple Creek Lot 1

Geo/Assessors code: 0000054101

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 225 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: · INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Jake Mertes, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

RECEIVED
OFFICE
FEB 23 2001
MT DEPT OF ENV QUALITY
PERMITTING & COMPLIANCE

Cripple Creek Sub.
Lincoln Co
SE1/4 Sec 17-T34N-R25W



Legend:
- ○ - PERC TEST
- □ - TEST HOLE
- ⓐ - WELL SITE W/100' ISOLATION ZONE
- ≡ - DRAINFIELD SITE
- ⋮ - REPLACEMENT AREA
- ▱ - MIXING ZONE
- ▨ - FLOODZONE

APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division
Tim Read 3-5-2001
Reviewer Date

1" = 100'