LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
AFFIDAVIT OF WASTEWATER TREATMENT AND DISPOSAL SYSTEM COMPLIANCE REVIEW FOR SYSTEM INSTALLED, REPAIRED OR REPLACED WITHOUT A VALID PERMIT

Issue Date: 12/6/2017

Property Owner: Jean Nordahl

Mailing Address: PO BOX 1693 Eureka, MT 59917

Telephone: (Home) [redacted] (Work)

Name of Person Who Installed System Being Reviewed: Barb Renkema

Type of System Work Reviewed:

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 85' laterals using gravelless chambers.

Property Description:

Legal: 0000000855 S9 T35 R26

Address or Location: Tract 1E

Reviewed Design Components:

Wastewater Flows: 225 Sewer Lines: Sched40 Septic Tank: 1000 Effluent Filter: Yes

Dosing or Lift Tank: n/a Drainfield Size: 170 Drainfield Construction: Gravelless

Hydraulic Function: yes

Comments:

System Review Documentation Statement:

I, Barb Renkema, have inspected/reviewed the components of this system as listed above and found it to be in compliance with the sizing, construction, orientation and operating requirements of Chapter 17, Subchapter 9 A.R.M., Circular DEQ-4 and Lincoln County Wastewater Regulation #3.

Signed: Barb Renkema *Date:* 2-6-18

Title: Insp 78

NOTICE: This document is not a permit for installation, repair or alterations of a wastewater treatment system. It is merely a statement of affirmation that the Department has conducted an on-site review of an otherwise illegal system and found it to be in compliance with all applicable requirements for that system. This affidavit effectively removes the illegal installation status on this system.

DISCLAIMER

This affidavit of review is not a guarantee by the Department that the system will continue to function properly for any prescribed period of time.

Jean-Paul Nordahl

S 9 T 35 N R 26 W

TR - 1E

10.095 A

