LINCOLN COUNTY
DEPARTMENT of ENVIRONMENTAL HEALTH
Wastewater Treatment and Disposal System
PERMIT

Issued Installer: Sign + Return

Issue Date: 03/11/98 Expiration Date: 03/12/99

Property Owner: Allen Riffel c/o: _____

Address: [redacted]

Telephone: (Home) [redacted] (Work) _____

Installer: Fred McDougall License No. 24

_____ New Installation XX Existing System

_____ Repair XX Replacement _____ Extension _____ Other

Describe: Replacing crushed lateral lines with 2-ring drywell system.

Parcel Description:

Legal: NW 1/4 NE 1/4 S18 T30 R33

Address or Location: 5687 Lake Creek Road

Approved Design Criteria: 2-Ring Drywell

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: _____ ~~lineal feet~~

INSTALL SYSTEM ACCORDING TO LOT LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: ***IF SOILS IN DRY-WELL EXCAVATION BED ARE POROUS, 12-INCHES OF SAND MUST BE PLACED BELOW DRY-WELL RINGS. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, Fred McDougal *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Fred McDougal *Date:* 3/12/98

Title: McDougall Enterprises

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT
ALLEN RIFFEL
5687 LAKE CREEK ROAD

