LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/07/2015 Expiration Date: 05/08/2016

Property Owner: Keith Smith c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: Melvin D. Smith License No. 99

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe:

Parcel Description:

Legal: S9 T32 R34

Address or Location: Lot 2 in Wild River Estates

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 255 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: Duane Smith *Date:* 5-12-15

Title: 99

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

EQN007-1834
2/22/07 TEL

LINCOLN COUNTY, MONTANA
LOT LAYOUT
WILD RIVER ESTATES
IN THE NE 1/4 OF SECTION 9
TWP. 32 N., R. 34 W., P.M.M.
FOR: DEBRA CERNICK DATE: NOVEMBER 2004



EQ#07-1834
APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division
Barbara Kingery 3-13-
Reviewer Date

DETAIL OF DITCH
1 1/2' TO 2'
WASHED ROCK
4X1
1'
3'

ALONG THE UPPER
DITCH LINES OF
APPROACH ROADS

LEGEND

- TP — SOILS PROFILE
- PT — PERCOLATION SITE
- W — PROPOSED WELL SITE
- STORMWATER POND 20'X 30'X 2'
- SLOPE
- GRADIENT DIRECTION
- PROPOSED SEPTIC SITE 3-56' TRENCHES 7' APART
- REPLACEMENT SITE 3-56' TRENCHES 7' APART