LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/26/2016 Expiration Date: 10/26/2017

Property Owner: Jeff Soule c/o: Bart Roose

Address: PO BOX 1996, Eureka, MT 59917

Telephone: (Home) (Work)

Installer: Koocanusa Excavating Inc. License No. 135

__XX__ New Installation ____ Existing System

____ Repair ___ Replacement ____ Extension ____ Other

Describe: Three 75' laterals using gravelless chambers

Parcel Description:

Legal: S6 T35 R27

Address or Location: Gut Creek Lot 1A 2642 Gut Creek Road

Geo/Assessors code: 0000055538

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 225 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

RECEIVED
JAN 12 2009
MT DEQ PUBLIC WATER
& SUBDIVISION BUREAU

LOT LAYOUT
ROOSE REWRITE
LOT 1A OF GUT CREEK SUBDIVISION

GOV'T LOTS 5 & 6, SEC. 6, T35N, R27W, P.M.,M.,
LINCOLN COUNTY, MONTANA
OWNERS: JEFF SOULE AND LeANN ROOSE

Reviewed by the Local Reviewing Authority
Under contract with the
Department of Environmental Quality/ PCD
Local Reviewer — Date 1/8/2009

Accepted under contract
Barbara Kingery — Date 1/13/09
DEQ Representative
EQ#09-1746

UNDEVELOPED W/IN 100'
N74°54'00"E
539.81'
589.81'
50.00'
GUT CREEK ROAD
L=214.05'
Δ=19°45'18"
R=620.82'
L=196.81'
Δ=19°45'18"
R=570.82'


LOT 1A
6.000 AC.±

UNDEVELOPED W/IN 100'
N00°01'42"W 421.49'
369.95'
HYDR. GRD. = 0.039
TRANSFORMER
TH #1
SLOPE 12%
HOUSE SITE
DITCH FLOW RETENTION SWALE 31 FEET
498.54'
557.64'
S46°12'13"W
UNDEVELOPED W/IN 100'
269.20'
N76°00'59"W
225.21'
N76°00'59"W
59.10'
GUT CREEK ROAD
APPROVED SEPTIC & REPLACEMENT EQ#27-94-S88-1260

LEGEND

- W1/4 CORNER SECTION 6, FOUND 3.25" DIAMETER BRASS CAP 1970
- SET 5/8" X 24" REBAR W/PLASTIC CAP STAMPED #13102LS
- FOUND 5/8" REBAR W/CAP STAMPED #7328S (UNLESS OTHERWISE NOTED)
- COMPUTED POINT
- PERCOLATION TEST
- TEST HOLE
- PROPOSED DRAINFIELD
- REPLACEMENT DRAINFIELD
- WELL SITE W/100' ISOLATION
- MIXING ZONE
- RETENTION SWALE (2' WIDE BY 1' DEEP-TO BE BUILT DOWN GRADIENT OF BUILDINGS AND DRIVEWAYS)
- X STAKED STRAW BALE

100' 0 100'



SWALE DETAIL
NOT TO SCALE

SAM CORDI
REGISTERED LAND SURVEYOR
974 COLORADO AVE.
P.O. BOX 323
WHITEFISH, MT 59937
PHONE: (406)-862-9977

BY: AARON J. GUZMAN
9/10/08