County

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 6/18/2015 Expiration Date: 6/19/2016

Property Owner: Ida M. Templin c/o:

Address: P.O. Box 1290 Troy, MT 59935

Telephone: (Home) (Work)

Installer: Tally Hoe License No. 1

____ New Installation ● Existing System

____ Repair ● Replacement ____ Extension ____ Other

Describe: Using gravelless chambers--sizing reduction allowed per drainfield size below

Parcel Description:

Legal: S24 T31 R34

Address or Location: 612 Templin Dr. #172 Troy, MT 59935

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 216 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kendra Lind

Closure Statement:

I, Thomas J Cole, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: Thomas J Cole Date: 6-24-15

Title: owner

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

N

← Slope — 1%

