LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

LOT 10

Issue Date: 7/26/2016 Expiration Date: 7/26/2017

Property Owner: Watson Family Trust, Hirdesh Lal c/o: Jerry Croskrey

Address: PO BOX 78, Fortine, MT 59918

Telephone: (Home) [redacted] (Work)

Installer: Ivan Miller License No. 52

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 84' trenches using gravelless chambers, size reduced per 0.4 gpd app rate

Parcel Description:

Legal: S26 T36 R28

Address or Location: Cato Subdivision, Lot 10 Kootenai Echo Trail, Rexford, MT

Geo/Assessors code: 0000055870

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 253 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Ivan Miller Jr, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Ivan Miller Jr *Date:* 8/26/16


Title: installer

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


N
KOOTENAI ECHO TRAIL
REPLACEMENT
3-5%
3x 84 Feet Chambers
DISTRIBUTION BOX
SEPTIC TANK
CLEAN OUT
329.99'
WATER LINE
LOT 10
184.73'