Licensed Installer
Sign & Return

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/19/02 Expiration Date: 11/20/03

Property Owner: Thomas T. & Rex E. Waters c/o: Thomas T. Waters

Address: 1100 Sherman Creek Road

Telephone: (Home) 889-3888 (Work)

Installer: John Chupp License No. 87

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: 500-gallon bay of 1500 gallon septic tank will be utilized for required lift station. 2-bedroom home being built, but system is adequately sized to accommodate 3-bedroom structure.

Parcel Description:

Legal: S9 T36 R26

Address or Location: Lot 5 in AB Subdivision

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 380 Linear Feet

Lift Station Size: 500 gallons

Special Instructions: INSTALL SYSTEM & LIFT STATION ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, John Chupp *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: John Chupp *Date:* 12/5/02

Title:

LOT LAYOUT
TOM WATERS
LOT #5
AB SUBDIVISION

