LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/01/2014 Expiration Date: 10/02/2015

Property Owner: John DeKok c/o: Kootenai Sand & Gravel, Inc.

Address: P.O. box 915 Eureka, MT 59917

Telephone: (Home) (Work) [redacted]

Installer: Kootenai Sand & Gravel License No. 109

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe:

Parcel Description:

Legal: S26 T35 R26

Address or Location: Lot 5 of Moose Farm Subdivision

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 300 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

RECEIVED

NOV 09 2006

Department of
Environmental Quality
Kalispell Regional Office

Name: Moose Farm Subdivision
owner- Winefordner
County: Lincoln
Location: SE ¼ sec.26-T35N-R26W
E.Q.#

Legend
- perc test
- test hole
- drainfield site
- replacement area
- well site w/ 100' isolation
- mixing zone


LOT 1
1.81 ACRES GROSS
1.36 ACRES NET


LOT 2
1.97 ACRES GROSS
1.80 ACRES NET

LOT 3
1.66 ACRES GROSS
1.32 ACRES NET

LOT 4
2.00 ACRES GROSS
1.83 ACRES NET


LOT 5
2.00 ACRES GROSS
2.00 ACRES NET






Stormwater Control Detail

to be installed down gradient of construction sites



Rock Check Dam

For sediment control along roadway
to be installed inside of road swales every 100 ft. on slopes > 5%
Rocks to be jagged edged
varied size from 4"in. to 12in.



Roadside Swale Detail

to be installed along both sides of roadway
culverts to be installed as needed
ditch sides @ 1 to 1 slope

N

1"=200'

Enviro-Tech
Consulting Inc.
PO Box 5674
Kalispell, MT 59903
(406)261-7565

APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division
Reviewer 11/29/06 Date

Revision for Lot 3 well site
Reviewed & approved Jenkins Bird, RS 11/26/2006
Lincoln County Department of Environmental Health