LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/03/2014 Expiration Date:

Property Owner: Donald Pate c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: William Robinson License No. 156

XX New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Installing pressure-dosed system per submitted Jere Johnson design

Parcel Description:

Legal: S33 T36 R25 COS #3201

Address or Location: Grave Creek Road

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 250 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL PRESSURE-DOSED SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

PATE PROPERTY

SECTION 33-T36N-R25W
LINCOLN COUNTY



HES 784
118.00ac

DRAINFIELD SIZING:
DEQ=0.4gpdpsf
300/0.4 = 750sf
UPD = 750sf/3 = 250lf / 3 = 3-84ft laterals
Proposed: 3-84ft laterals , 7ft centers, 3ft trench depth

LEGEND

PRIMARY / REPLACEMENT DRAINFIELD

TEST HOLE

N

1" = 200'

Jere Johnson, RS
4572 Whitefish Stage Road
Whitefish MT 59937