LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/23/2014 Expiration Date: 12/24/2015

Property Owner: Todd & Claire Reno c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: Terry Oedewaldt License No. 2

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Using gravelless chambers – sizing reduction allowed per "Drainfield Size" below.

Parcel Description:

Legal: Lot 1B of Swede Mountain Lookout Estates

Address or Location: 399 Cottonwood Lane

Approved Design Criteria:

Bedrooms: 5 Septic Tank Size: 1500 gallons Drainfield Size: 500 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER


This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

AMENDED LOT 1 SWEDE MTN LOOKOUT ESTATES
LOT LAYOUT

NOVEMBER 2001
LINCOLN COUNTY, MONTANA

APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division

Tim Reed 11-12-2001
Reviewer Date



LEGEND

- APPROVED WELL LOCATION
- APPROVED DRAINFIELD
- REPLACEMENT AREA
- GROUNDWATER FLOW DIRECTION

RECEIVED
OFFICE
DEC 4 2001
MT DEPT OF ENV QUALITY
PERMITTING & COMPLIANCE DIV

KSI
KOOTENAI SURVEYORS INC.
P.O. BOX 393
LIBBY, MT 59923
(406)293-4354

1 INCH = 200 FEET