LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/10/2014 Expiration Date: 09/11/2015

Property Owner: Tim & Christy Rusdal c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work) [redacted]

Installer: Terry Oedewaldt License No. 2

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: System for five bedroom residence and shop with Lavatory – 6-bedroom equivalency sizing. Using gravelless chambers – sizing reduction allowed per "Drainfield Size" below.

Parcel Description:

Legal: S32 T29 R30 Lot 2 of Cowell Creek Subdivision

Address or Location: 9107 Farm to Market Road

Approved Design Criteria:

Bedrooms: 5 Septic Tank Size: 2000 gallons Drainfield Size: 300 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442


DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Legend

- perc test
- test hole
- proposed drainfield site
- proposed replacement area
- proposed well site w/ 100' isolation zone
- mixing zone

Name: Cowell Creek Subdivision
owner- Lord
County: Lincoln
Location: sec.32-T29N-R30W
E.Q.#



- COWELL CREEK ROAD CENTERLINE DATA

LABEL		BEARING	LENGTH
L11		S75°04'32"E	219.49'
<L11>		<S69°37.4'E>	<164.3'>
CURVE	RADIUS	DELTA	LENGTH
C10	600.00'	22°37'43"	236.97'
<C10>	<600'>	<26°41.2'>	<279.5'>

LOT 2
6.54 ACRES

N

1" = 200'

Enviro-Tech
Consulting Inc.
PO Box 5674
Kalispell, MT 59903
(406)257-2795