LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/12/2014 Expiration Date: 05/13/2015

Property Owner: Charley Robert Shappard c/o:

Address:

Telephone: (Home) (Work)

Installer: Charles Riley License No. 147

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Using gravelless chambers – sizing reduction allowed per "Drainfield Size" below.

Parcel Description:

Legal: S5 T29 R33 Lot 1 in Keeler View Subdivison

Address or Location: 72 Camp View Drive

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 204 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY, MONTANA
LOT LAYOUT
KEELER VIEW
IN THE S1/2 OF SECTION 5,
TWP. 29 N., R. 33 W., P.M.M.

FOR: S&S RESOURCES, L.L.C. DATE: AUGUST 2006

EQ# 07-1504
APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division
Barbara Kingery 4-19-07
Reviewer Date

LEGEND

- SOILS PROFILE
- PERCOLATION SITE
- EXISTING WELL SITE
- STORMWATER POND 20'X 30'X 2'
- SLOPE
- GRADIENT DIRECTION
- PROPOSED SEPTIC SITE 3-85' TRENCHES 10' APART
- REPLACEMENT SITE 3-85' TRENCHES 10' APART
- 200' MIXING ZONE

NO WELLS OR SEPTIC WITH IN 100' OF PROPERTY BOUNDARIES

GRADIENT DIRECTION

LOT 1
7.60 ACRES±

LOT 2
6.21 ACRES±

LOT 3
11.13 ACRES±

R= 100'

R= 100'

R= 100'

SLOPE 2%

SLOPE 2%

SLOPE 3%

TIMBER LINE

KEELER VIEW DRIVE

CAMP

DETAIL OF DITCH
1 1/2" TO 2"
WASHED ROCK
4X1 4X1
1' 3'

ALONG THE UPPER DITCH LINES OF APPROACH ROADS

SCALE
1 INCH = 200 FT.

RECEIVED
SEP 19 2006
MT. DEQ PUBLIC WATER & SUBDIVISIONS BUREAU

Davis Surveying Inc.
TROY MONTANA, (406)295-5441

DATE: 08/22/06	
DRAWN BY: MSM	FILE: S&S.DWG