LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/07/2013 Expiration Date: 11/08/2014

Property Owner: Chris & Brenda Hocher c/o: Greg K. Hanson, MH HOA

Address: P.O. Box 1975 Eureka, MT 59917

Telephone: (Home) [redacted] (Work)

Installer: Stewart Homes Affiliation/License No.: Building Contractor

XX Direct Connection _____ Grinder Pump Connection _____ Lift Tank Connection

Describe: Sewer line connection to sewer main for approved Drainfield D-3. Owner will be constructing a 2-bedroom living unit that will be replacing current RV hookup.

Parcel Description:

Legal: Lot 78 in Phase III of Mariners Haven

Address or Location:

Approved Design Criteria:

The Mariners Haven Environmental HOA has approved construction of a two-bedroom living unit with a maximum wastewater flow of 225 gallons per day to replace the existing RV hookup on this Lot. This Lot has DEQ approval for development with up to a 2-bedroom structure with wastewater not to exceed 225 gallons per day. Any proposed increase that would exceed the DEQ approved 2-bedroom/225 gallons per day limitation would require prior review and approval by the Montana DEQ Subdivision Section and authorization of the Mariners Haven HOA. Any activities that result in occupancy and wastewater flows exceeding those approved by E.Q. #08-2971 without prior DEQ review and approval is in violation of the conditions of approval and subject to enforcement action.

Special Instructions: INSTALL DIRECT SEWERLINE CONNECTION TO THE SEWER MAIN LINE FOR DRAINFIELD D-3 ACCORDING TO THE LOT LAYOUT AND DEQ APPROVAL STATEMENT E.Q. 08-2971. ANY DEVIATIONS FROM APPROVED PLAN MUST HAVE PRIOR AUTHORIZATION FROM THE MARINERS HAVEN ENVIRONMENTAL HOA, DEQ AND THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the DEQ Approval Statement requirements.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to installation of the connection. Any connection installation not inspected by the Department or its designated representative is considered an illegal connection and may be subject to fines and/or requirements to remove or reconstruct the connection.


406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that this connection will function properly for a prescribed period of time.

MARINERS HAVEN DESIGN GUIDELINES	Environmental Review Board	Form #: ERB Revision: Date:

Design Approval Application Form



An elevation layout must be drawn showing the following:

✓ Grade elevation to primary structure peak

TO BE COMPLETED BY THE ENVIRONMENTAL REVIEW BOARD

DEQ Approval: ☐ Yes ☐ No. Lincoln County Approval: ☐ Yes ☐ No. ERB & HOA Approval: ☒ Yes ☐ No

Approved with Conditions: ☐ Yes

Comments/Conditions:

November 1, 2013
Date:

Environmental Review Board Approval Signature(s)