LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 01/28/2014 Expiration Date: 01/29/2015

Property Owner: Brad Jones II c/o:

Address: P.O. Box 442 Troy, MT 59935

Telephone: (Home) [redacted] (Work) [redacted]

Installer: Larry Bowman License No. 15

____ New Installation __XX__ Existing System

_____ Repair __XX__ Replacement_____ Extension _____ Other

Describe: Replacing existing failed pressure-dosed system (soils saturated) with elevated sand mound in new location.

Parcel Description:

Legal: NW-1/4 NE-1/4 S4 T30 R33 Tract 2B

Address or Location: 3637 Bull Lake Road

Approved Design Criteria:

Bedrooms: 3 Existing Septic Tank Size: 1000 gallons Drainfield Size: 300 Square Foot Sand-Mound

Existing Dose Tank Size: 500 gallons

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL ELEVATED SAND-MOUNG SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, Kendra J. Lind *reviewed, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Kendra J. Lind *Date:* 01/28/2014

Title: R.S.

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

