LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 03/09/2009 Expiration Date: 03/10/2010

Property Owner: Montana Fish Wildlife & Parks c/o: Mark McNearney, Project Manager

Address: [redacted]

Telephone: (Office) [redacted] (Cell) [redacted]

Installer: Flathead Concrete Products—Latrine Supplier

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Installation of single sealed vault privy unit at Crystal Lake public fishing access site.

Parcel Description:

Legal: Tract 2D in SW-1/4 S19 T27 R27 COS #1759

Address or Location: Crystal Lake via East Lakeshore Drive

Approved Design Criteria:

FAS Type Latrine With 1200 gallon vault

Special Instructions: INSTALL SEALED VAULT LATRINE SYSTEM ACCORDING TO SITE PLAN, FLOOR PLAN & ELEVATIONS DETAILS, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.