LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/9/2025 Expiration Date: 12/8/2026 (FINAL RENEWAL) Permit#25-59710

Property Owner: Kevin Rider 2nd.Renewal Prior Owner Dorothy Eisenman

Address: [redacted] 3rd & 4th(Welch Renewal)

Installer: Richard Luciano License No. 3

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension __XX__ Other (RENEWAL)

Describe: Five 96' Laterals using chambers.

Parcel Description:

Legal: CYHAWK ESTATES, S29, T36 N, R27 W, ACRES 11.367, LOT 8 PM 7174

Address or Location: 266 Kenny Road Rexford, MT 55930 Assessment Code: 59710

DEQ COSA: EQ#10-1309 Date: 6/12/14

Approved Design Criteria: Installation of new gravity system for 4 Bedroom House with 5 Laterals @ 96'.

Bedrooms: 4 Septic Tank Size: 1500 gallons Drainfield Size: 480 Lineal Feet

of Laterals: 5 Length of Laterals: 96' Trench Width: 24" Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, R.S.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.


Signed: _____ *Date:* _____

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2444

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.


STORMWATER
DETENTION
EASEMENT
111.17'
132.00'
82.42'
311.02'
374.63'
357.00'
STORMWATER
DETENTION
EASEMENT
255.85'
STORMWATER
DETENTION
EASEMENT
Lot 8
11.367 acres
586.26'
749.03'
465.75'
624.76'