LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/10/05

Expiration Date: 06/11/06

Property Owner: Charles & Dorothy Newton

c/o: Koocanusa Plumbing & Electric

Address: [redacted]

Telephone: (Home)

(Work) [redacted]

Installer: Koocanusa Plumbing & Electric

License No. 8

____ New Installation

__XX__ Existing System

_____ Repair __XX__ Replacement _____ Extension _____ Other

Describe: Replacing failed drainfield. Existing 900-gallon septic tank is in good condition and is being retained.

Parcel Description:

Legal: NE-1/4 SW-1/4 S11 T36 R27

Address or Location: Tracts 6A1-6A2-6A4-A6

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 900 gallons Drainfield Size: 150 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, Richard B Nelson, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Richard B Nelson *Date:* 21 June 2005

Title: Septic Tank Installer #8

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

This Drawing is of the Northwest Corner of the 23.155 Acres
Tracts 6A1-6A2-6A4 & 6A6 ID #7578
NE¼ SW¼ Sect. 11 T36N R27W

